



City of Sanford, Maine
Facilities Department

919 Main Street, Sanford, Maine 04073-3589
(207) 324-9130 FAX (207) 324-9142



CITY OF SANFORD/VILLAGE OF SPRINGVALE, MAINE

ADDENDUM TO BID

FOR: DUCTLESS SPLIT AIR CONDITIONING SYSTEM – CITY HALL

The following changes are hereby made to the bid package:

INSTRUCTIONS TO BIDDERS – Article 7, Qualifications of Bidders

The following line is struck from the article:


“The bidder must also submit documentation that they are certified in Erosion Control by the MDEP and are approved to work in the Shoreland Zone.”

This qualification is not pertinent to the proposed work and was included in error.

SPECIFICATIONS – Ductless Split Cooling System

Use of two separate outdoor units, one for each of the indoor air handlers, is an acceptable alternative to a single outdoor unit supplying both indoor units.

This alternative is being made because some of the more common manufacturers of HVAC equipment don't manufacture multizone systems with outdoor units that meet the low ambient controls requirements.

 10/14/2021
Alex Hammerle, Director of Facilities