



Town of Sanford

Fire Department

Office of the Fire Marshal

Office: 53 River St. Sanford Maine 04073

Mailing: 972 Main St. Sanford, Maine 04073

firemarshal@sanfordmaine.org



MEMORANDUM FOR COMMON CODE VIOLATIONS WITHIN A SPECIAL EVENT

The following codes have been listed for your reference:

NFPA 1 2006 25.1.5.2 The ground enclosed by any tent or temporary membrane structure and for a reasonable distance, but not less than 10 ft (3 m) outside of such structure(s), shall be cleared of all flammable or combustible material or vegetation. This work shall be accomplished to the satisfaction of the AHJ prior to the erection of such structure(s). The premises shall be kept free from such flammable or combustible materials during the period for which the premises are used by the public.

NFPA 1 2006 25.1.6.3 Portable fire-extinguishing equipment of approved types shall be furnished and maintained in tents and temporary membrane structures by the person operating any assembly occupancy in such amount and in such locations as directed by the AHJ.

NFPA 96 2008 4.1.9 Cooking equipment used in fixed, mobile, or temporary concessions, such as trucks, buses, trailers, pavilions, tents, or any form of roofed enclosure, shall comply with this standard.

4.1.1 Cooking equipment used in processes producing smoke or grease-laden vapors shall be equipped with an exhaust system that complies with all the equipment and performance requirements of this standard.

10.1.1 Fire-extinguishing equipment for the protection of grease removal devices, hood exhaust plenums, and exhaust duct systems shall be provided.

10.1.2* Cooking equipment that produces grease-laden vapors and that might be a source of ignition of grease in the hood, grease removal device, or duct shall be protected by fire-extinguishing equipment.

NFPA 58 2009 6.6.5 Temporary Container Installations.

6.6.5.1 Single containers constructed as portable storage containers for temporary stationary service in accordance with 5.2.7.2(A) shall be placed on concrete pads, paved surfaces, or firm earth for such temporary service (not more than 12 months at a given location).

(A) The legs or supports, or the lugs for the attachment of legs or supports, shall be secured to the container in accordance with the ASME code under which the container was designed and built.

6.6.5.3 Flexibility shall be provided in the connecting piping in accordance with 6.9.6.